

ROOM DATA SHEET / LISTADO DE SALAS

Project: Salas blancas para BSL2
Client: Leitat
System: --
Doc. Code: 021LEI01-DCL-GEN-N01
Page:

Client approval:

Name		Signature	
Date			

Version	Object	Written by	Reviewed by	Date
A	Ingeniería	FAR	CSR	10/11/2021



ROOM DATA SHEET / LISTADO DE SALAS

Doc. Code: 021LEI01-DCL-GEN-N01

Version: A

Ver.	Floor	Code	Description	Dimensions			ISO Grade	AHU number	EXT number	Conditions		
				Height	Area	Volume				Temperature	Humidity	Pressure (ΔP)
-	-	-	-	m	m²	m³	-	-	-	°C	%	Pa
A	B1	001	ALMACÉN AMBIENTE	2,70	13,03	35,18	D	UTA-001	-	20±2°C	NC	25
A	B1	002	SAS MATERIALES	2,70	5,74	15,50	D	UTA-001	-	20±2°C	NC	10
A	B1	003	SAS PERSONAL	2,70	6,55	17,69	D	UTA-001	-	20±2°C	NC	10
A	B1	004	ALMACÉN FRIO	2,70	16,72	45,14	D	UTA-001	-	20±2°C	NC	25
A	B1	005	VESTÍBULO	2,70	17,02	45,95	D	UTA-001	-	20±2°C	NC	20
A	B1	006	PRE SAS PERSONAL 2	2,70	7,14	19,28	C	UTA-002	-	20±2°C	NC	30
A	B1	009	SAS PERSONAL 2	2,70	5,55	14,99	B	UTA-002	-	20±2°C	NC	40
A	B1	010	SALA ISO 5	2,70	17,53	47,33	B	UTA-002	EXT-001	20±1°C	NC	50
A	B1	010a	PASS BOX ENTRADA	0,60	0,39	0,23	B	UTA-002	-	20±2°C	NC	40
A	B1	010b	PASS BOX SALIDA	0,60	0,39	0,23	B	UTA-002	-	20±2°C	NC	40
A	B1	007	PRE SAS 1 PERSONAL 1	2,70	3,88	10,48	C	UTA-003	-	20±2°C	NC	30
A	B1	008	SAS PERSONAL 1	2,70	4,19	11,31	B	UTA-003	-	20±2°C	NC	40
A	B1	011	SALA ISO 5	2,70	18,01	48,63	B	UTA-003	EXT-002	20±1°C	NC	50
A	B1	011a	PASS BOX ENTRADA	0,60	0,39	0,23	B	UTA-003	-	20±2°C	NC	40
A	B1	011b	PASS BOX SALIDA	0,60	0,39	0,23	B	UTA-003	-	20±2°C	NC	40